

**DESCRIPTION OF THE  
DAMPIER TO BUNBURY  
NATURAL GAS PIPELINE SYSTEM  
AS AT  
1 JANUARY 2025**



## **TABLE OF CONTENTS**

---

1.	Introduction	1
2.	Description of the DBNGP System: Inlet Points, Outlet Points and Notional Gate Points	2
3.	Description of the DBNGP System: Component Parts	15

## **1. Introduction**

The Dampier to Bunbury Natural Gas Pipeline (“DBNGP”) is owned by DBNGP (WA) Nominees Pty Ltd as Trustee for the DBNGP (WA) Pipeline Trust and is operated by DBNGP (WA) Transmission Pty Ltd (“DBP”).

The DBNGP system is described in Section 2. The boundaries of the system are defined by the system’s inlet and outlet points and notional gate points.

At inlet points, custody and title of gas transfers from shippers to DBP. Facilities upstream of the inlet points are constructed, owned and operated by shippers or by parties other than DBP.

At outlet points, custody and title of gas transfers from DBP to shippers. Facilities downstream of the outlet points are constructed, owned and operated by shippers or by parties other than DBP.

Section 3 describes the major component parts of the DBNGP system.

## 2. Description of the DBNGP System: Inlet Points, Outlet Points and Notional Gate Points

The schematic on the following pages describe the DBNGP system in terms of its inlet and outlet points.

“Inlet point” means *a flange or joint or other point specified in a gas transportation contract as the point at which the shipper delivers gas to DBP under the contract.* Table 1 defines each of the inlet points in the DBNGP system.




“Branching Points” have no contractual significance but serve to identify points of branching from the main pipeline. Each Branching Point can have more than one outlet point attached to it.

“Outlet point” means *a flange or joint, notional gate point or other point specified in a gas transportation contract as a point at which DBP delivers gas to the shipper under the contract.* Table 2 defines each of the outlet points.

“Notional gate point” means the point at which custody of the gas transfers from DBP to a shipper for delivery into a distribution sub-network. Each notional gate point is defined in Table 3 which also shows the associated outlet points.

“BEP Capacity” means the accessible capacity under the BEP Lease Agreement between BEP Owners and DBP *to deliver DBNGP gas using the BEP Pipeline.*


The following designations are used in the schematic and tables:

Symbol	Designation	Description
<b>Ixx -xx GAS INLET</b>	Ixxx-xx	Inlet Point xxx-xx
■	BP-zzz	Branching Point zzz
■	Ozzz-yy	Outlet Point yy on the Branch zzz
□	aa-b	Inline metering facility for check metering and non-billing operation purposes. Eg, KJ-A represents Kwinana Junction M2A inline meter station
	CSn	Compressor Station CSn
	MLVnnn	Mainline Valve number nnn
		BEP Capacity as part of BEP Lease Agreement

Number of inlet points	Active	10
	Inactive	1
Number of branching points	Active	43
	Under Construction	0
	Inactive	4
Number of outlet points	Active	56
	Under Construction	0
	Inactive	7
Number of notional gate points		12


(Note: “Inactive” Inlet or Outlet points refer to inactive, not used or decommissioned inlet/outlet points).

*Dampier To Bunbury Natural Gas Pipeline  
Description of the Gas Transmission System*



Continued to Next Page

*Dampier To Bunbury Natural Gas Pipeline  
Description of the Gas Transmission System*



**TABLE 1  
GAS TRANSMISSION SYSTEM: INLET POINTS**

LOCATION	POINT DESIGNATION	DISTANCE FROM DAMPIER (Pipeline kilometres)	DESCRIPTION
DOMGAS Dampier Plant	I1-01	0.000	Inlet point is at the upstream flange of the flange joint upstream of the monolithic insulation joint on the main gas pipeline within the Dampier facilities compound.
Pluto	I1-05	2.245	Inlet point is at the upstream flange of the insulating joint between upstream ZV001 and the HV01 Valve at hottap location. This Inlet Point is located inside the Pluto Metering Compound.
MLV7 Interconnect Inlet	I1-03	21.968	Inlet point is at the PEP side flange of isolation valve HV5020 located on the meter run 3/4 within MLV7 compound
Devil Creek	I1-04	58.66	Inlet point is located at the insulation joint downstream of the hot-tap valve within the offtake compound.
Harriet	I1-02	136.924	Inlet point is at the second insulation gasket upstream of valve ZV1 between the Harriet meter station and the mainline interconnecting pipe. This gasket is located inside the Harriet meter compound.
Gorgon	I2-01	137.750	Inlet point is at the below ground insulation joint at the boundary of the 30m DBNGP easement
Macedon	I2-02	223.138	Inlet point is at the below ground insulation joint at the boundary of the 30m DBNGP easement
Wheatstone	I3-03	272.662	Inlet point is located within the Wheatstone Pig Receiver Facilities on either: <ul style="list-style-type: none"> <li>• the first insulation gasket on the interconnecting pipe between the Wheatstone Pig Receiver Facilities and the ZV2 Compound located on CS2 Emergency Station Bypass. This gasket is located inside the Wheatstone Pig Receiver Facilities.</li> <li>• the first insulation gasket on the interconnecting pipe between the Wheatstone Pig Receiver Facilities and the Wheatstone Interconnect Compound located downstream of MLV30 on the DBNGP. This gasket is located inside the Wheatstone Pig Receiver Facilities.</li> </ul>
Waitsia Inlet	I8-02	1041.435	Inlet point is at the connecting flange at fence line between the adjacent Waitsia Pipeline Pig Receiver Compound (owned by others) and the DBNGP Waitsia Inlet Station compound.
Mondarra Storage Facilities	I8-01	1,043.678	Inlet point is at the below ground insulation joint (PC3) at the western boundary of the 40m extended DBNGP easement.
Red Gully (Inactive)	I10-01	1,266.624	Inlet point is at the below ground insulation joint at the boundary of the 30m DBNGP easement

*Dampier To Bunbury Natural Gas Pipeline  
Description of the Gas Transmission System*

	<b>DESCRIPTION</b>
KGP Backflow (formerly BEP Capacity Point)	<p>“BEP Capacity” means the accessible capacity under the BEP Lease Agreement between BEP Owners and DBP to deliver DBNGP gas using the BEP Pipeline. BEP Capacity is for forward flow from Karratha Gas Plant to the DBNGP via the BEP. Gas delivery to the BEP is measured at the KGP BEP metering station within the KGP Gas Plant</p> <p>“KGP Backflow” refers to the same delivery point as the BEP Capacity which is at the buried insulation joint at the outer buffer fence of the Karratha Gas Plant on the Burrup Peninsula and located at KP0 on the BEP Pipeline. KGP Backflow is for back flowing of gas from the DBNGP to Karratha Gas Plant via the BEP. Backflow gas delivery to KGP is measured at O16-01 MLVL7 Backflow Meter Station</p>
KJ-B	Inline metering facilities at Kwinana Junction for measuring the Pressure Service supporting the Outlet Point HEGT (OKW-05)



**TABLE 2  
GAS TRANSMISSION SYSTEM: BRANCHING POINTS AND OUTLET POINTS**

<b>LOCATION</b>	<b>POINT DESIGNATION</b>	<b>DISTANCE FROM DAMPIER (Pipeline kilometres)</b>	<b>DESCRIPTION</b>
Branching Point Pluto	BP-14	2.245	This is a branching point located at the insulation joint downstream of the hot-tap valve within the metering compound
Pluto	O14-01	2.245	Outlet point is at the insulating joint downstream of Pluto meter station. This joint is located outside the meter compound.
Branching Point Burrup Fertilisers	BP-10	3.574	This is a branching point located at the insulation gasket downstream of the hot-tap valve within the Burrup Fertilisers metering compound
Burrup Fertilisers	O10-01	3.574	Outlet point is at the insulation gasket downstream of the venturi nozzle RO019 located within the Burrup Fertilisers metering compound
Branching Point MLV7	BP-12	21.933	This is a branching point located at the first reducer downstream of HV100A and HV100B valves located inside the MLV7 compound.
PEP Interconnect	O12-02	21.968	Outlet point is at the spectacle-blind upstream joint located downstream of the meter station.
MLV7 Interconnect Outlet	O12-03	21.968	Outlet point is at the PEP side flange of isolation valve HV5020 located on the meter run 3/4 within MLV7 compound
Robe River	O12-01	22.083	Outlet point is at the reducer on the downstream side of the odorant injection facility at the outlet of Cajaput Well meter station.
7 Mile	O12-04	21.950	Outlet point is at the last insulating joint downstream of the meter runs. This joint is located inside the MLV 7 compound.
Branching Point MLVL7 Backflow	BP-16	22.188	This is a branching point located at the barred tee upstream of the mainline valve MLVL7 located at the Loop 0 pig launcher facilities inside the MLVL7 compound.
MLVL7 Backflow	O16-01	22.188	Outlet point is at the upstream flange of the isolation valve HV290 within the MLVL7 Backflow meter station
Branching Point Maitland	BP-13	29.993	This is a branching point located at the insulation gasket downstream of the hot-tap valve within the metering compound
Maitland	O13-01	29.993	Outlet point is at the downstream flange of the drop-out spool downstream of the hand valve HV134 within the meter station
Branching Point Cape Preston	BP-15	82.490	This is a branching point located at the insulation joint downstream of the hot-tap valve within the metering compound
Cape Preston	O15-01	82.490	Outlet point is at the insulating joint downstream of Cape Preston meter station. This joint is located outside the meter compound.
Branching Point GGP Interconnect	BP-21	137.2	This is a branching point located at the connection downstream of the station bypass line within the Compressor Station at CS1
GGP Interconnect	O21-01	137.2	Outlet point is on the downstream pipe linking the DBNGP and the GGT and at the intersection between the DBNGP and the GGT easements

**TABLE 2  
GAS TRANSMISSION SYSTEM: BRANCHING POINTS AND OUTLET POINTS**

LOCATION	POINT DESIGNATION	DISTANCE FROM DAMPIER (Pipeline kilometres)	DESCRIPTION
Branching Point FRGP	BP-22	137.2	This is a branching point located on downstream flange of the hot-tap valve HV262 on CS1 emergency station bypass pipe
FRGP	O22-01	137.2	Outlet point is the upstream joint of the spectacle-blind flange located upstream of the hand valve ZV 002
Branching Point Ashburton (Inactive)	BP-32	272.644	This is a branching point on CS 2 emergency station bypass pipe located upstream of valve ZV2.
Ashburton	O32-01	272.644	Outlet point is downstream of valve SDV5101.
Branching Point AOGP (Inactive)	BP-34	272.644	This is a branching point located downstream of the first insulation gasket downstream of valve ZV1. This gasket is located inside MLV30 compound.
AOGP	O34-01	272.644	Inlet point is at the second insulation gasket downstream of valve ZV1 between the MLV30 Compound and the Wheatstone Pig Receiver Facilities. This gasket is located inside the Wheatstone Pig Receiver Facilities compound.
Branching Point Wheatstone Delivery	BP-33	272.662	This is a branching point located at the downstream flange of the isolation valve ZV3 within the Wheatstone Interconnect Compound
Wheatstone Delivery	O33-01	272.662	Outlet point is on either one of the following: <ul style="list-style-type: none"> <li>• the second insulation gasket downstream of valve ZV2 on the interconnecting pipe between the ZV2 Compound and the Wheatstone Pig Receiver Facilities. This gasket is located inside the Wheatstone Pig Receiver Facilities.</li> <li>• the second insulation gasket downstream of valve ZV3 on the interconnecting pipe between the Wheatstone Interconnect Compound and the Wheatstone Pig Receiver Facilities. This gasket is located inside the Wheatstone Pig Receiver Facilities.</li> </ul>
Branching Point Woodhouse Wells	BP-31	311.586	This is a branching point located at downstream of the hot-tap valve within the metering compound
Woodhouse Wells (Exmouth PS)	O31-01	311.586	Outlet point is on the downstream flange of the reducer downstream of the insulation joint within the meter compound
Branching Point MLV55	BP-51	578.858	This is a branching point located at the first flanged joint downstream of HV100A and HV100B located at the MLV55 compound.
Brown Range	O51-02	743.118	Outlet point is at the insulation joint downstream of the pig receiver located at the end of the Brown Range lateral and at the boundary of the Mungullah Power Station – Note that this outlet point is downstream and use the same meter as outlet point O51-01
Carnarvon Power Station	O51-01	748.583	Outlet point is at the insulation joint downstream of the pig receiver located at the Carnarvon Power Station.
Branching Point MLV90	BP-85	967.096	This is a branching point located at the pipeline junction between valve HV205C and HV206 inside the MLV90 compound.

**TABLE 2  
GAS TRANSMISSION SYSTEM: BRANCHING POINTS AND OUTLET POINTS**

LOCATION	POINT DESIGNATION	DISTANCE FROM DAMPIER (Pipeline kilometres)	DESCRIPTION
Eradu Road	O85-01	967.116km	Outlet point is at the first isolation joint located downstream of Eradu Road meter station located inside the MLV90 compound.
Branching Point NGI	BP-87	967.150km	This is a branching point located at the upstream flange of HV001 downstream of the NGI hottap fitting on the DBNBP Loopline 7.
NGI	O87-01	967.150km	Outlet point is at the downstream flange of the first isolation gasket located downstream of the Restriction Nozzle 137 located inside NGI meter station.
Branching Point MLV91	BP-81	996.544	This is a branching point located at the first reducer downstream of HV100A and HV100B located at the MLV91 compound.
Nangetty Road	O81-01	996.851	Outlet point is at the first insulation flange located downstream of the injection line of the odorant facility. This insulating flange is located inside the Nangetty Road compound.
Mungarra Power Station	O81-02	999.126	Outlet point is on the upstream side of the isolation valves on each gas turbine generating unit located downstream of pressure relief valves.
Branching Point Mondarra Storage	BP-86	1,043.678	This is a branching point located on the downstream flange of valve HVMON02 located inside the Mondarra Storage Meter Station.
Mondarra Storage	O86-01	1,043.678	Outlet point is at the below ground insulation joint (PC3) at the western boundary of the 40m extended DBNGP easement.
Branching Point Pye Road	BP-82	1043.730	This is a branching point located on the downstream flange of valve HV001 located inside the Pye Road meter station compound.
Mondarra (Inactive)	O82-01	1043.740	Outlet point is at the insulating gasket downstream of Mondarra meter station. This gasket is located inside the Mondarra compound.
Pye Road	O82-02	1043.765	Outlet point is at the insulating flange upstream of the odorant injection point, located inside the Boral compound at the Pye Road meter station.
Branching Point MLV93	BP-84	1054.211	This is a branching point located at the first insulating joint on the supply line to the meter station. The insulating joint is located in the MLV93 compound.
Mount Adams Road (Inactive)	O84-01	1054.216	Outlet point is at the first insulation joint located downstream of Mount Adams Road meter station located inside the MLV 93 compound.
Branching Point CS8	BP-83	1113.551	This is a branching point located on the downstream side of HV105B. The branching point is located in the MLV95 and Eneabba meter station compound.
Eneabba	O83-01	1113.621	Outlet point is at the insulation joint downstream of the launcher isolating valve.
Branching Point Muchea	BP-P1	1307.000	This is a branching point located at the downstream flange of HV1 located in the Muchea meter station compound.
Muchea (Inactive)	OP1-01	1307.036	Outlet point is at the reducer located downstream of the odorant injection facility.

**TABLE 2  
GAS TRANSMISSION SYSTEM: BRANCHING POINTS AND OUTLET POINTS**

<b>LOCATION</b>	<b>POINT DESIGNATION</b>	<b>DISTANCE FROM DAMPIER (Pipeline kilometres)</b>	<b>DESCRIPTION</b>
Branching Point Neerabup	BP-P10	1309.835	This is a branching point located at the insulation joint downstream of the hot-tap valve within the metering compound
Neerabup	OP10-01	1309.835	Outlet point is at the insulating joint downstream of meter station. This joint is located outside the meter compound.
Branching Point MLV117	BP-P9	1323.931	This is a branching point comprising the downstream flanges of valves HV100A and HV100B located inside the MLV117 compound.
Della Road Meter Station (MLV117)	OP9-01	1323.996	Outlet point is at the insulating joint upstream of the distribution system valve pit located outside the MLV117 compound.
Branching Point MLV116	BP-P2	1311.157	This is a branching point located on the downstream side of the HV 100A valve located inside the MLV116 compound.
Pinjar Power Station	OP2-01	1326.157	Outlet point is on the upstream side of isolation valves on each gas turbine generating unit located downstream of pressure relief valves.
Branching Point MLV118	BP-P3	1336.740	This is a branching point located at the first insulation joint on the supply line to the Ellenbrook meter station. This insulation joint is located inside the MLV118 compound.
Ellenbrook	OP3-01	1336.750	Outlet point is at the first insulation joint located downstream of valve HV010.
Branching Point Harrow Street	BP-P4	1343.510	This is a branching point located at the first tee upstream of HV100A on the 350mm inlet header to the Harrow Street meter station.
Harrow Street	OP4-01	1343.610	Outlet point is on the upstream side of the second outlet valve located downstream of odorant injection facility.
Branching Point MLV119	BP-P5	1347.339	This is a branching point located at the first reducer downstream of valves HV100A and HV100B located inside the MLV119 compound.
Caversham	OP5-01	1347.434	Outlet point is at the insulation joint located downstream of the odorant injection facility.
Branching Point MLV120	BP-P6	1359.664	This is a branching point located at the first reducer downstream of valves HV100A and HV100B inside the MLV120 compound.
Welshpool	OP6-01	1359.714	Outlet point is on the upstream side of the second outlet valve located downstream of the odorant injection facility.
Branching Point MLV122	BP-P7	1379.695	This is a branching point located at the first reducer downstream of valves HV100A and HV100B inside the MLV122 compound.
Forrestdale	OP7-01	1379.750	Outlet point is on the upstream side of the second outlet valve located downstream of the odorant injection facility.
Branching Point MLV129	BP-P8	1398.638	This is a branching point located on the downstream side of valve HV700 located on the inlet side of the Russell Road pre-regulation set. The point is adjacent to the Kwinana Junction scrubber bypass.
Russell Road	OP8-01	1408.183	Outlet point is on the upstream side of the second outlet valve located downstream of the odorant injection facility.
Branching Point Kwinana Junction	BP-KJ	1399.000	This is a branching point located at the centreline of the valve HV401A, located in the Kwinana Junction compound.

**TABLE 2  
GAS TRANSMISSION SYSTEM: BRANCHING POINTS AND OUTLET POINTS**

LOCATION	POINT DESIGNATION	DISTANCE FROM DAMPIER (Pipeline kilometres)	DESCRIPTION
Branching Point Inlet to W LPG	BP-LPGI	1401.997	This branching point is at the first insulating flange located downstream of the pressure reducing valve PV035.
Branching Point Second Outlet from W LPG	BP-LPGOSO	1401.997	This branching point is at the insulating gasket upstream of the AGR metering facility located at the second return line from the W LPG plant.
W LPG	OPLPGI-01	1402.025	Outlet point is at the second insulating flange located downstream of the pressure reducing valve PV035.
Branching Point Outlet from W LPG	BP-LPGO	1402.066	This branching point is at the first insulating flange upstream of valve V14 located on the return line from the W LPG plant.
AGR	OPLPGOSO-01	1402.297	Outlet point is at the spectacle blind located on the downstream side of the restriction nozzle/blind located downstream of the AGR meter skid.
Branching Point Kwinana West	BP-KW	1405.217	This is a branching point located at 500 to 300 reducer located upstream of valves KLV3 and KLV4.
Branching Point KLV1	BP-RK	1405.327	This is a branching point located at the downstream side of valve VB11 located upstream of the Thomas Road Meter Station offtake.
Burton Place	ORK-06	1405.327	Outlet point is downstream of insulation joint. This joint is downstream of valve HV056 inside CS 10 compound.
Thomas Road	ORK-05	1407.620	Outlet point is on the upstream side of the TiWest valve located inside the TiWest cogeneration facility.
BP Cogen	ORK-01	1407.716	Outlet point is at the upstream flange of the isolation valve (HV017) located downstream of the meter skid.
Mason Road	ORK-02	1409.647	Outlet point comprises the upstream flange of the second valve located downstream of the pig receiver of the BP Kwinana lateral and the first insulation gasket downstream of the first valve located downstream of the pig receiver of the BP Kwinana lateral.
Kwinana Power Station (Inactive)	OKW-02	1409.651	Outlet point is at the insulating gasket on the downstream side of the meter station outlet valve HV501A.
Cockburn PS / NewGen	OKW-04	1409.651	Outlet point is at the insulation gasket on the downstream side of the sonic nozzle (F0439).
HEGT	OKW-05	1409.651	Outlet point is at the insulation joint on the downstream side of the sonic nozzle (RO 001).
Barter Road	OKW-03	1409.751	Outlet point comprises the upstream flange of the second meter station outlet valve downstream of the insulation joint and the upstream flange of the valve located downstream of the insulation joint.
Alcoa Kwinana	OKW-01	1410.557	Outlet point comprises the outlet flanges on the downstream side of the meter station outlet valves HV601A and HV601B.

**TABLE 2  
GAS TRANSMISSION SYSTEM: BRANCHING POINTS AND OUTLET POINTS**

LOCATION	POINT DESIGNATION	DISTANCE FROM DAMPIER (Pipeline kilometres)	DESCRIPTION
KNR (Previously known as WMC)	ORK-04	1410.837	Outlet point comprises the upstream side of the second isolating valve located on the KNR boundary for the high pressure line and the insulation joint located upstream of the second isolation valve for the low pressure line.
Rockingham	ORK-03	1410.857	Outlet point comprises the: i) upstream flange of the meter station outlet valve located downstream of the odorant injection facilities. ii) upstream flange of the second valve located downstream of the CSBP pipe.
Branching Point South 1	BP-S1	1449.456	This is a branching point located at the first insulating flange downstream of valve HV001 located upstream of the MLV143 compound.
Branching Point Mandurah	BP-S9	1434.870	Branching point is downstream of valve HV03. This valve is located downstream of insulating joint inside the meter compound.
Mandurah	OS9-01	1434.870	Outlet point is at the insulating joint upstream of pig launcher compound. This joint is located inside the offtake compound.
Pinjarra Town	OS1-01	1449.476	Outlet point is on the upstream side of the second outlet valve located downstream of the odorant injection facility.
Branching Point South 2	BP-S2	1458.106	This is a branching point located at the anchor flange located downstream of valve PLV1 located inside the MLV143 compound.
Oakley Road (Inactive)	OS2-02	1462.592	Outlet point is at the insulation gasket located downstream of valve HV105.
Alcoa Pinjarra	OS2-01	1463.426	Outlet point comprises the outlet flanges on the downstream side of the meter station outlet valves HV601A and HV601B
Pinjarra Cogen	OS2-03	1463.426	Outlet point is at the upstream side of the insulation gasket located downstream of valve BV-12 and spectacle flange.
Branching Point South 3	BP-S3	1489.329	This is a branching point located at the first tee upstream of MLV150 located inside the Wagerup West compound.
Alcoa Wagerup	OS3-01	1498.857	Outlet point comprises the outlet flanges on the downstream side of the meter station outlet valves HV601A, HV601B and HV004.
Wagerup Cogen	OS3-02	1498.857	Outlet point is at the upstream side of the insulation gasket located downstream of hand valve HV412 and 350x350 expander.
Branching Point South 8	BP-S8	1507.18	This is a branching point located on the downstream side of the hand valve HV012 located inside the MLV154/155 compound.
Kemerton PS	OS8-01	1511.91	Outlet point is at the upstream flange of the drop out spool located downstream of the insulation gasket downstream of the pressure reduction skid
Branching Point South 4	BP-S4	1513.630	This is a branching point located at the first tee upstream of the insulation joint adjacent to MLV154 located inside the MLV154 compound.

**TABLE 2  
GAS TRANSMISSION SYSTEM: BRANCHING POINTS AND OUTLET POINTS**

<b>LOCATION</b>	<b>POINT DESIGNATION</b>	<b>DISTANCE FROM DAMPIER (Pipeline kilometres)</b>	<b>DESCRIPTION</b>
Branching Point South 7	BP-S7	1513.635	This is a branching point located on the tee at the junction of the SW loop and the Worsley Cogeneration lateral, below ground in the MLV154/155 compound.
Branching Point Wellesley	BP-S10	1516.821	The branching point is at the upstream flange of the aboveground main isolation valve ZV104, downstream of the buried hottap valve HV101
Wellesley	OS10-01	1516.821	Outlet point is at the aboveground connecting flange at the boundary fence, downstream of the Isolation Valve HV275 located within the Wellesley Meter Station.
Harvey	OS4-01	1522.096	Outlet point is at the upstream flange of the isolation valve located downstream of the odorant injection facility.
Branching Point South 5	BP-S5	1525.104	This is a branching point located on the downstream side of the offtake valve HV1 located inside the Kemerton meter station.
Kemerton	OS5-01	1525.124	Outlet point is at the upstream flange of the valve located downstream of the insulation joint.
Branching Point South 6	BP-S6	1530.439	This is a branching point located at the first reducer downstream of MLV156 and situated in the Clifton Road compound.
Clifton Road	OS6-01	1530.457	Outlet point is at the first insulating joint located downstream of the odorant injection facility.
South West Cogeneration	OS7-01	1546.000	Outlet point is at two locations, the first being the insulating flange located downstream of the meter skids, and the second being downstream of the Meter Run #3 and downstream of the insulating flange and the 250x200 reducer inside the South West Cogeneration consumer valve compound.
Worsley	OS4-02	1546.620	Outlet point is at the flange downstream of the insulation joint located downstream of the meter station outlet valve.

**TABLE 3  
GAS TRANSMISSION SYSTEM: NOTIONAL GATE POINTS**

NOTIONAL GATE POINT	ASSOCIATED OUTLET POINT/S	TRANSMISSION OUTLET POINT/S DESIGNATION
NGP - Nangetty Rd	Nangetty Road	O81-01
NGP - Eneabba	Eneabba	O83-01
NGP - Muchea	Muchea	OP1-01
NGP - Ellenbrook	Ellenbrook	OP3-01
NGP - North Metro	Della Rd Harrow Street Caversham	OP9-01 OP4-01 OP5-01
NGP - South Metro	Welshpool Forrestdale Russell Road	OP6-01 OP7-01 OP8-01
NGP - Barter Road	Barter Road	OKW-03
NGP - Rockingham	Rockingham Mandurah	ORK-03 OS9-01
NGP - Pinjarra	Pinjarra Town Oakley Road	OS1-01 OS2-02
NGP - Harvey	Harvey	OS4-01
NGP - Kemerton	Kemerton	OS5-01
NGP - Clifton Road	Clifton Road	OS6-01

NGP - “name”      Notional gate point - “name”



### **3. Description of the DBNGP System: Component Parts**

The principal component parts of the DBNGP system are:

- a) the main line between the Karratha Gas Plant near Dampier and Clifton Rd, Australind near Bunbury;
- b) gas turbine driven centrifugal compressor units and associated facilities including aftercoolers;
- c) main line valves;
- d) laterals;
- e) outlet stations;
- f) Kwinana Junction metering station;
- g) supervisory control and data acquisition (SCADA) system and the associated microwave communications facility; and
- h) odorising facilities.

#### **General Description**

The DBNGP system comprises high pressure gas transmission pipeline, including laterals, and associated compression plant, and valves, linking gas suppliers in the north west of Western Australia with markets principally in the South West.

The DBNGP system is not a single continuous entity, and consists of the following major parts.

#### Dampier to Kwinana Section

The Dampier to Kwinana section is rated and operates at 8.48MPa. It delivers gas to all part haul outlet points, and to all full haul outlet points between Compressor Station 9 (CS9) and Kwinana Junction. Five laterals ranging in diameter from 350mm (14 inches) to 150mm (6 inches) are connected to this pipeline section. The main line loops to Wesfarmers LPG Plant at Kwinana Junction. Under an arrangement with Wesfarmers LPG Pty Ltd, gas leaves the system at a point immediately upstream of the company's LPG extraction plant at Kwinana and is returned to the system immediately downstream of the plant.

#### Kwinana Junction

Kwinana Junction, 1,399km downstream of Dampier, is a major junction in the gas transmission system. All gas delivered to Kwinana West Lateral, Rockingham Lateral, WLPG Plant and Pipeline South passes through Kwinana Junction. Facilities for gas quality measurement upstream and downstream of the LPG plant are also located at Kwinana Junction.

#### Kwinana West Lateral

This section is rated at 6.89MPa and operates at approximately 4.5MPa. It consists of three different pipes ranging in diameter from 500mm (20 inches) to 200mm (8 inches). The Kwinana West Lateral delivers gas to outlet points at Alcoa Kwinana, Kwinana Power Station, and to the outlet point at Barter Road.

#### Rockingham Lateral

A short 180m long, 600mm (18 inches) pipeline provides a link between the suction of CS10 and Rockingham lateral. The Rockingham lateral and the link are rated at 6.89MPa and operate at approximately 4.5MPa. They consist of three different pipes ranging in diameter from 300mm (12 inches) to 150mm (6 inches). The Rockingham Lateral delivers gas to outlet points in the Kwinana industrial area and supplying the distribution system serving Rockingham and Mandurah.

#### Pipeline South

Compressor Station Number 10 (CS10) is located at the beginning of Pipeline South. Pipeline South MAOP is 6.89MPa. It consists of three different pipes ranging in diameter from 500mm (20 inches) down to 200mm (8 inches). It terminates at MLV157 located at Clifton Road, north of Bunbury. Five laterals ranging in diameter from 450mm (14 inches) to 250mm (10 inches) are connected to this pipeline section. The pipeline section between MLV150 and MLV154 is looped with 18" diameter pipeline. The Pipeline South delivers gas to outlet points at Alcoa Pinjarra, Alcoa Wagerup, Worsley Alumina, South West Cogen, Kemerton Power Station, and to outlet points supplying the distribution systems at Pinjarra Town, Oakley Road, Harvey, Kemerton and south of Clifton Road.

#### Stage 4, 5A and 5B Looping Sections

The 26" diameter loop sections have been designed, constructed and tested to operate at 10.2MPa, but are currently operated at the same pressure as the existing Mainline. Stage 4 consists of 217km loops in 10 sections immediately downstream of CS1 to CS10. Stage 5A loops continue from stage 4 for another 571km. Stage 5B loops continue 430km from stage 5A but also includes the eleventh section from MLV 7 to CS 1. This is called loop 0.

The physical characteristics of the main pipeline and laterals are in the following Tables 4 and 5. The details for the looped sections are set out in Table 6.

#### Mainline Valves

Areas through which the DBNGP passes are classified (in accordance with Australian Standard 2885) as broad rural R1 and suburban T1. In areas classified as R1, main line valves are spaced approximately 30km apart on the Mainline and 60km apart on the loops. They are approximately 10km apart in areas classified as T1. The majority of the mainline valves can be remotely actuated from the control centre.

“MAOP” denotes maximum allowable operating pressure.

**TABLE 4  
MAIN LINE: PHYSICAL CHARACTERISTICS**

<b>SECTION: DAMPIER TO KWINANA JUNCTION</b>		
Length	1,311.2km	87.4km
Nominal size	660mm	660mm
Wall thickness	8.74mm	12.7mm
Steel type	API 5LX 65 DSAW	API 5LX 65 DSAW
MAOP	8,480kPa (gauge)	8,480kPa (gauge)
<b>SECTION: KWINANA JUNCTION - WLPG PLANT - KWINANA JUNCTION</b>		
Length	6.4km	
Nominal size	660mm	
Wall thickness	14.27mm	
Steel type	API 5LX 65 DSAW	
MAOP	8,480kPa (gauge)	
<b>SECTION: KWINANA JUNCTION TO MAIN LINE VALVE 141</b>		
Length	10.8km	
Nominal size	500mm	
Wall thickness	7.94mm	
Steel type	API 5LX 65 DSAW	
MAOP	6,890kPa (gauge)	
<b>SECTION: MAIN LINE VALVE 141 TO MAIN LINE VALVE 150</b>		
Length	73.5km	
Nominal size	500mm	
Wall thickness	5.56mm	
Steel type	API 5LX 65 DSAW	
MAOP	6,890kPa (gauge)	
<b>SECTION: MAIN LINE VALVE 150 TO MAIN LINE VALVE 154</b>		
Length	23.9km	
Nominal size	250mm	
Wall thickness	4.80mm	
Steel type	API 5LX 52 ERW	
MAOP	6,890kPa (gauge)	
<b>SECTION: MAIN LINE VALVE 154 TO MAIN LINE VALVE 157</b>		
Length	16.9km	
Nominal size	200mm	
Wall thickness	4.80mm	
Steel type	API 5LX 52 ERW	
MAOP	6,890kPa (gauge)	

**TABLE 5  
GAS TRANSMISSION SYSTEM LATERALS (CONTINUED)**

<b>HAMERSLEY IRON</b>		
Length	0.5km	
Nominal size	200mm	
Wall Thickness	6.4mm	
Steel Type	API 5LX 52 ERW	
MAOP	8,480kPa (gauge)	
<b>GGT INTERCONNECT</b>		
Length	1.48km	
Nominal size	300mm	
Wall Thickness	9.5mm	
Steel Type	API 5LX42	
MAOP	10,200kPa (gauge)	
<b>GGT INTERCONNECT INLET PIPE</b>		
Length	0.515km	
Nominal size	400mm	
Wall Thickness	8.06mm	
Steel Type	API 5LX70	
MAOP	8,480kPa (gauge)	
<b>CARNARVON</b>		
Length	163.7km	7.4km
Nominal size	150mm	150mm
Wall Thickness	4.8mm	6.4mm
Steel Type	API 5LX 42 ERW	API Grade B ERW
MAOP	8,480kPa (gauge)	1,900kPa (gauge)
<b>BROWN RANGE LATERAL</b>		
Length	0.59km	
Nominal size	150mm	
Wall Thickness	10.97mm	
Steel Type	API 5LX 42 ERW	
MAOP	8,480kPa (gauge)	
<b>MUNGARRA</b>		
Length	2.5km	
Nominal size	150mm	
Wall Thickness	6.4mm	
Steel Type	API 5L Grade B ERW	
MAOP	8,480kPa (gauge)	
<b>PINJAR</b>		
Length	14.2km	
Nominal size	350mm	
Wall Thickness	7.1mm	
Steel Type	API 5LX 52 ERW	
MAOP	8,480kPa (gauge)	

**TABLE 5  
GAS TRANSMISSION SYSTEM LATERALS (CONTINUED)**

<b>RUSSELL ROAD</b>			
Length	7.3km		
Nominal size	300mm		
Wall Thickness	9.5mm		
Steel Type	API 5LX 46 ERW		
MAOP	6,890kPa (gauge)		
<b>KWINANA WEST</b>			
Length	2.0km	2.8km	1.5km
Nominal size	500mm	350mm	200mm
Wall Thickness	7.9mm	9.5mm	8.7mm
Steel Type	API 5LX 65DSA W	API 5LX 52 ERW	API Grade B ERW
MAOP	6,890kPa (gauge)	6,890kPa (gauge)	6,890kPa (gauge)
<b>CS10 TO ROCKINGHAM LATERAL PIPELINE (ROCKINGHAM LATERAL LINK)</b>			
Length	0.18km		
Nominal size	600mm		
Wall thickness	12.65mm		
Steel type	API 5LX 70 ERW		
MAOP	6,890kPa (gauge)		
<b>ROCKINGHAM</b>			
Length	3.2km	2.6km	
Nominal size	300mm	150mm	
Wall Thickness	9.5mm	6.4mm	
Steel Type	API 5LX 46 ERW	API 5L Grade B ERW	
MAOP	6,890kPa (gauge)	6,890kPa (gauge)	
<b>KNC/BP (Part of Rockingham Lateral Located Downstream of Mason Road Outlet Station)</b>			
Length	1.6km		
Nominal size	250mm		
Wall Thickness	9.3mm		
Steel Type	API 5LX 42 ERW		
MAOP	6,890kPa (gauge)		
<b>COGEN (Part of Rockingham Lateral Located Downstream of Cogen Outlet Station)</b>			
Length	0.9km		
Nominal size	200mm		
Wall Thickness	8.2mm		
Steel Type	API 5LX 42 ERW		
MAOP	6,890kPa (gauge)		
<b>TIWEST COGENERATION LATERAL (Part of Rockingham Lateral)</b>			
Length	0.58km		
Nominal size	150mm		
Wall Thickness	7.1mm		
Steel Type	API 5LX 42 ERW		
MAOP	6,890kPa (gauge)		

**TABLE 5  
GAS TRANSMISSION SYSTEM LATERALS (CONTINUED)**

<b>ALCOA PINJARRA</b>		
Length	2.5km	2.9km
Nominal size	300mm	300mm
Wall Thickness	7.1mm	9.5mm
Steel Type	API 5L Grade B ERW	API 5LX 52 ERW
MAOP	6,890kPa (gauge)	6,890kPa (gauge)
<b>ALCOA WAGERUP</b>		
Length	8.0km	1.5km
Nominal size	350mm	350mm
Wall Thickness	7.1mm	9.5mm
Steel Type	API 5L Grade B ERW	API 5LX 42 ERW
MAOP	6,890kPa (gauge)	6,890kPa (gauge)
<b>WORSLEY</b>		
Length	32.9km	
Nominal size	250mm	
Wall Thickness	4.8mm	
Steel Type	API 5LX 52 ERW	
MAOP	6,890kPa (gauge)	
<b>SOUTH WEST COGENERATION LATERAL</b>		
Length	32.9km	
Nominal size	450mm	
Wall Thickness	6.35mm	
Steel Type	API 5LX 60 ERW	
MAOP	8,280kPa (gauge)	
<b>KEMERTON POWER STATION LATERAL</b>		
Length	4.94km	
Nominal size	300mm	
Wall Thickness	6.4mm	
Steel Type	API 5LX 42 ERW	
MAOP	6,900kPa (gauge)	
<b>WELLESLEY LATERAL</b>		
Length	0.705km	
Nominal size	200mm	
Wall Thickness	5.6mm	
Steel Type	API 5LX 52 ERW	
MAOP	6,900kPa (gauge)	

**TABLE 6  
LOOPING SECTIONS**

<b>LOOP 0 (DOWNSTREAM OF MLV 7)</b>	
Length	114.948km
Nominal size	660mm
Wall Thickness	8.72mm
Steel Type	API 5LX 70 ERW
MAOP	Current Operating 8,480kPag, Design 10,200kPag
<b>LOOP 1 (DOWNSTREAM OF CS1)</b>	
Length	134.513km
Nominal size	660mm
Wall Thickness	8.72mm
Steel Type	API 5LX 70 ERW
MAOP	Current Operating 8,480kPag, Design 10,200kPag
<b>LOOP 2 (DOWNSTREAM OF CS2)</b>	
Length	121.929km
Nominal size	660mm
Wall Thickness	8.72mm
Steel Type	API 5LX 70 ERW
MAOP	Current Operating 8,480kPag, Design 10,200kPag
<b>LOOP 3 (DOWNSTREAM OF CS3)</b>	
Length	119.851km
Nominal size	660mm
Wall Thickness	8.72mm
Steel Type	API 5LX 70 ERW
MAOP	Current Operating 8,480kPag, Design 10,200kPag
<b>LOOP 4 (DOWNSTREAM OF CS4)</b>	
Length	120.580km
Nominal size	660mm
Wall Thickness	8.72mm
Steel Type	API 5LX 70 ERW
MAOP	Current Operating 8,480kPag, Design 10,200kPag
<b>LOOP 5 (DOWNSTREAM OF CS5)</b>	
Length	119.530km
Nominal size	660mm
Wall Thickness	8.72mm
Steel Type	API 5LX 70 ERW
MAOP	Current Operating 8,480kPag, Design 10,200kPag
<b>LOOP 6 (DOWNSTREAM OF CS6)</b>	
Length	117.320km
Nominal size	660mm
Wall Thickness	8.72mm
Steel Type	API 5LX 70 ERW
MAOP	Current Operating 8,480kPag, Design 10,200kPag

<b>LOOP 7 (DOWNSTREAM OF CS7)</b>	
Length	110.13km
Nominal size	660mm
Wall Thickness	8.72mm
Steel Type	API 5LX 70 ERW
MAOP	Current Operating 8,480kPag, Design 10,200kPag
<b>LOOP 8 (DOWNSTREAM OF CS8)</b>	
Length	123.20km
Nominal size	660mm
Wall Thickness	8.72mm
Steel Type	API 5LX 70 ERW
MAOP	Current Operating 8,480kPag, Design 10,200kPag
<b>LOOP 9 (DOWNSTREAM OF CS9)</b>	
Length	90.54km
Nominal size	660mm
Wall Thickness	8.72mm
Steel Type	API 5LX 70 ERW
MAOP	Current Operating 8,480kPag, Design 10,200kPag
<b>LOOP 10 (DOWNSTREAM OF CS10)</b>	
Length	71.01km
Nominal size	660mm
Wall Thickness	8.72mm
Steel Type	API 5LX 70 ERW
MAOP	Current Operating 8,480kPag, Design 10,200kPag
<b>SOUTHERN LOOPING (MAIN LINE VALVE 145 TO MAIN LINE VALVE 154)</b>	
Length	24.3km
Nominal size	450mm
Wall thickness	6.35mm
Steel type	API 5LX 60 ERW
MAOP	8,280kPa (gauge)

## Compressor Stations

Ten compressor station sites are spaced at intervals of about 140km along the main line. Gas turbine driven centrifugal compressors at these stations are used to maintain pipeline pressure to meet natural gas demand.

A summary of compression plant is presented in Table 7.



**TABLE 7  
COMPRESSOR STATIONS**

COMPRESSOR STATION	DISTANCE FROM DAMPIER (KM)	GAS TURBINE DRIVER
Pluto Compressor	2.245	Waukesha L36GSI/GLD 750hp (10MW)
1	137.2	Unit 1 Solar Mars 15000hp (10MW) Unit 2 Solar Mars 15000hp (10MW)
2	272.1	Unit 1 General Electric LM500(Inactive) (4MW) Unit 2 Solar Mars 15000hp (10MW) Unit 3 Solar Mars 15000hp (10MW)
3	409.3	Unit 1 Solar Mars 15000hp (10MW) Unit 2 General Electric Model LM500 (Inactive) (4MW) Unit 3 Solar Mars 15000hp (10MW)
4	546.9	Unit 1 General Electric LM500 (Inactive) (4MW) Unit 2 Solar Mars 15000hp (10MW) Unit 3 Solar Mars 15000hp (10MW)
5	684.8	Unit 1 Solar Mars 15000hp (10MW) Unit 2 Solar Mars 15000hp (10MW)
6	824.9	Unit 1 General Electric Model LM500 (Inactive) (4MW) Unit 2 Nuovo Pignone PGT10 (10MW) Unit 3 Solar Mars 15000hp (10MW)
7	966.6	Unit 1 General Electric LM500 (Inactive) (4MW) Unit 2 Solar Mars 15000hp (10MW) Unit 3 Solar Mars 15000hp (10MW)
8	1114.1	Unit 1 Solar Mars 15000hp (10MW) Unit 2 Solar Mars 15000hp (10MW)
9	1256.8	Unit 1 Nuovo Pignone PGT10 (10MW) Unit 2 Solar Mars 15000hp (10MW)
10	1402.3	Unit 1 Solar Centaur 4000hp (Inactive) (3.0MW) Unit 2 Solar Centaur 4000hp (Inactive) (3.0MW) Unit 3 Solar Taurus 10000hp (7MW) Unit 4 Solar Taurus 10000hp (7MW)

### Aftercoolers

Aftercoolers are installed immediately downstream of the inlet point I1-01, and immediately downstream of CS1 to CS10 compressor stations. The aftercoolers have been designed to control the downstream gas temperature below 45°C.

## **Outlet and Inlet Stations**

DBP owns and operates outlet stations on the DBNGP.

“Outlet station” means *either a gate station or the metering equipment site associated with an outlet point, and includes all facilities installed at the site to perform overpressure protection, reverse flow protection, excessive flow protection, gas metering and measurement, and telemetry, and all standby, emergency and safety facilities, and all ancillary equipment and services.*

Inlet stations are located upstream of the inlet points to the DBNGP system and are owned and operated by parties other than DBP.

## **SCADA and Communication Systems**

The DBNGP SCADA and Communication Systems provide Supervisory, Control and Data Acquisition (SCADA) functionality for Compressor Stations, Main Line Valves, Meter stations and other associated facilities. It also provides all telephony, mobile voice radio, corporate ethernet and local area network connections.

The DBNGP SCADA system is critical in the monitoring and controlling of the pipeline operation, and the collection and storage of pipeline data required for the physical and commercial operation. It is a Telvent Oasys DNA 7.5 System located at DBP Head Office as well as a fully functional backup system at DBP Jandakot depot.

The DBNGP communication network is separated into two parts. The Northern Network covers the pipeline section from Dampier to Perth while the Southern Network covers the section from Perth to Bunbury. The Northern Network is a digital system fully owned and operated by DBP. Support and infrastructure for the Southern Network from Perth to Bunbury is shared between Western Power and DBP, however a communication upgrade project is current being carried out to convert this into a fully owned and operated DBP system.

## **Odorising**

Gas in the main pipeline between Karratha Gas Plant and the Wesfarmers LPG plant at Kwinana is not odorised. Upstream of Kwinana Junction, gas is odorised at outlet stations with the exception of those stations serving the Port Hedland Pipeline and the Geraldton area. Gas into the Geraldton area is odorised at the Nangetty Road outlet station. Downstream from Kwinana Junction, gas is odorised in accordance with the *Gas Standards Act* sufficient for commercial/industrial use. The level of odorant is increased at outlet stations delivering gas into the distribution sub-networks.